

PLUMBING INSPECTION WORK ORDER

DATED: _____

PERMIT #: _____

CONTRACTOR: _____

ADDRESS: _____

PLUMBING INSPECTOR
RAY COLE
269-409-6021

WILL BE LOOKING AT:

- Fixture units
- Fixture vents
- Piping Material Waste
- Piping Material Vents
- Pipe Supports
- Nail Guard Protection Plate at Top & Bottom of Plate
- Nail Guard on Studs
- Pipe Slope Vent & Waste
- Sanitation Vertical Only
- Underground Inspection before covering
- Fire Stopped – TO BE DONE ON ROUGH INSP.
- Air Pressure Water Lines 50# - TO BE DONE ON ROUGH INSP.
- Water Heater Valve Supply
- Water Heater Relief Discharge Pipe 4" from floor
- Water Heater Dielectric
- Water Heater No CPVC within 12" of Heater
- Supply Material
- Supply Line Supported
- Air Hammer Device
- Air Admittance Valve
- Air Admittance Valve 4" up
- Roof Vent 3" through roof
- Roof Vents Terminate at least 12" above the Roof
- Vent Line Slope Down from Vent
- Connection off Different Materials